



NOTES: _____

1.0 MATERIAL:

1.1 DUCTILE IRON: GRADE 604018

2.0 FINISH:

2.1 HOT DIP GALVAINZE PER ASTM A-153 SPEC'S

3.0 BASE DESIGNED FOR FLAT OR ROUND SURFACES

4.0 TO ORDER BRACKET GROUNDING BOLT ADD "-GB" TO CATALOG NO.

EXAMPLE: SWB-86-12-GB

5.0 TO ORDER BRACKET AND CLAMP GROUNDING BOLTS ADD "-GB2" TO CATALOG NO.

EXAMPLE: SWB-86-12-GB2

UNLESS SPECIFIED
 DIM. TOL. - ± 1/16"
 HOLE TOL. - ± 1/32"
 ANGLES - ± 1°

PROPRIETARY

This information is confidential and is the property of Maclean Power Systems. It may not be made public or reproduced except that the customer may make copies for use solely in the installation, maintenance, and operation of products supplied by Maclean Power Systems.



MacLean Power Systems

Continental Electric

PO Box 835, Trussville, AL 35173

Phone: (205)655-7400 Fax: (205)655-3530



DRAWN BY: M.H.

APPROVED BY:

CHECKED BY:

SCALE: NONE

STATIC WIRE BRACKET

SWB-86-12

NO.	DATE	DESCRIPTION	BY	DATE:	DRAWING NO:	SH: 1	R / 0
REVISIONS				02-23-99	CEA-3398	OF: 1	