



7801 Park Place Rd. York, SC 29745 USA (803) 628-2100

H3 90 10 040 CX SS 023 MPS Catalog Number: Date: 05/20/2021 **End Fittings** Gain/12"-14" Hole Spacing Tower End Fitting: Anchor / Galv. Ductile Iron 2 HL Drop Tongue / Galv. Ductile Iron Line End Fitting: **Material** Corona Ring (Tower): None Corona Ring (Line): None Corona Rings are recommended for applications of 230 kV and above Mounting Angle: 17 deg 23 Number of Sheds: Rod Diameter: 3 in Weight Estimate: 102.1 lbs 46 kg **Dimensional Values** Section Length (L): 53.7 in 1,364 mm 40 in Rubber Length (X): 1,016 mm Shed spacing (S): 1.6 in 41 mm 2.7 in 68 mm Shed Projection (P): Dry Arc Distance: 43 in 1,092 mm 151.9 in Leakage Distance: 3,858 mm **Electricals Values** 60 Hz dry Flashover (Min. Withstand): 411 kV 386 kV 381 kV 60 Hz Wet Flashover (Min. Withstand): 299 kV CIFO Positive (Min. Withstand): 709 kV 633 kV CIFO Negative (Min. Withstand): 783 kV 672 kV **Mechanical Values** Max. Design Cant. Load (MDCL): 3.026 lbs 13.5 kN Specified Cant. Load (SCL): 6,052 lbs 26.9 kN Specified Tensile Load (STL): 20.000 lbs 89.0 kN

This drawing contains confidential information that is the property of MacLean Power, L.L.C. ("MacLean"). Use of MacLean's confidential information without MacLean's express written consent is strictly prohibited and may expose you to legal liability. If you believe that you received this material in error, please destroy it or return it to "MacLean Power, L.L.C., 7801 Park Place Rd., York, South Carolina 29745, USA."





Dimension: inches [millimeters]

NOTE: Drawing not actual depiction of insulator appearance.

Silicone rubber sheath and sheds complies with applicable ANSI and IEC standards.

Notes:

Prepared By: Laurel Wallace