



7801 Park Place Rd. York, SC 29745 USA (803) 628-2100

H3 90 10 046 CX SS 027 MPS Catalog Number: Date: 05/20/2021 **End Fittings** Gain/12"-14" Hole Spacing Tower End Fitting: Anchor / Galv. Ductile Iron 2 HL Drop Tongue / Galv. Ductile Iron Line End Fitting: **Material** Corona Ring (Tower): None Corona Ring (Line): None Corona Rings are recommended for applications of 230 kV and above Mounting Angle: 17 deg 27 Number of Sheds: Rod Diameter: 3 in Weight Estimate: 109.1 lbs 49 kg **Dimensional Values** Section Length (L): 59.4 in 1,509 mm 46 in Rubber Length (X): 1,168 mm Shed spacing (S): 1.6 in 41 mm 2.7 in 68 mm Shed Projection (P): 49 in Dry Arc Distance: 1,245 mm 177.4 in 4,506 mm Leakage Distance: **Electricals Values** 60 Hz dry Flashover (Min. Withstand): 464 kV 436 kV 430 kV 60 Hz Wet Flashover (Min. Withstand): 340 kV CIFO Positive (Min. Withstand): 804 kV 716 kV CIFO Negative (Min. Withstand): 857 kV 757 kV **Mechanical Values** 12.1 kN Max. Design Cant. Load (MDCL): 2.723 lbs Specified Cant. Load (SCL): 5,446 lbs 24.2 kN Specified Tensile Load (STL): 20.000 lbs 89.0 kN

This drawing contains confidential information that is the property of MacLean Power, L.L.C. ("MacLean"). Use of MacLean's confidential information without MacLean's express written consent is strictly prohibited and may expose you to legal liability. If you believe that you received this material in error, please destroy it or return it to "MacLean Power, L.L.C., 7801 Park Place Rd., York, South Carolina 29745, USA."





Dimension: inches [millimeters]

NOTE: Drawing not actual depiction of insulator appearance.

Silicone rubber sheath and sheds complies with applicable ANSI and IEC standards.

Notes: