



7801 Park Place Rd. York, SC 29745 USA (803) 628-2100

H3 90 10 106 CB SS 065 MPS Catalog Number: Date: 05/20/2021 **End Fittings** Gain/12"-14" Hole Spacing Tower End Fitting: Anchor / Galv. Ductile Iron 2 HL Drop Tongue / Galv. Ductile Iron Line End Fitting: **Material** Corona Ring (Tower): None Corona Ring (Line): 12" Corona Ring Corona Rings are recommended for applications of 230 kV and above Mounting Angle: 17 deg 65 Number of Sheds: Rod Diameter: 3 in Weight Estimate: 182.3 lbs 83 kg **Dimensional Values** Section Length (L): 116.8 in 2,967 mm 106 in Rubber Length (X): 2,692 mm Shed spacing (S): 1.6 in 41 mm 2.7 in 68 mm Shed Projection (P): 106.4 in Dry Arc Distance: 2,703 mm 422.4 in 10,729 mm Leakage Distance: **Electricals Values** 60 Hz dry Flashover (Min. Withstand): 952 kV 893 kV 831 kV 60 Hz Wet Flashover (Min. Withstand): 697 kV CIFO Positive (Min. Withstand): 1673 kV 1469 kV CIFO Negative (Min. Withstand): 1684 kV 1533 kV **Mechanical Values** 1.258 lbs 5.6 kN Max. Design Cant. Load (MDCL): Specified Cant. Load (SCL): 2,516 lbs 11.2 kN Specified Tensile Load (STL): 20.000 lbs 89.0 kN

This drawing contains confidential information that is the property of MacLean Power, L.L.C. ("MacLean"). Use of MacLean's confidential information without MacLean's express written consent is strictly prohibited and may expose you to legal liability. If you believe that you received this material in error, please destroy it or return it to "MacLean Power, L.L.C., 7801 Park Place Rd., York, South Carolina 29745, USA."





Dimension: inches [millimeters]

NOTE: Drawing not actual depiction of insulator appearance.

Silicone rubber sheath and sheds complies with applicable ANSI and IEC standards.

Notes:

Prepared By: Laurel Wallace