


MACLEAN POWER SYSTEMS

Reliable Power Products 11411 Addison, Franklin Park, IL 60131 USA (847) 455-0014

Catalog Number: Date:	END FITTINGS / MATERIAL		\$148071MX01 06/29/2009		
Tower End Fitting: Line End Fitting:			Y-Clevis Ball (ANSI 52-5)		
Corona Ring (towe Corona Ring (line):	r):			none none	
Number of Sheds: Weight Estimate:		17	.5 Lbs	38 7.9 kg	
DIMENSIONAL VALUES					
Section Length (A) Shed Diameter (B): Shed Spacing (C): Dry Arc Distance: Leakage Distance:		3 1.! 63	.7 In 3.7 In 57 In 3.4 In 3.7 In	1,820 mm 94 mm 40 mm 1,611 mm 3,930 mm	
ELECTRICAL VALUES					
60 Hz Dry F.O.(Min 60 Hz Wet F.O.(Min CIFO + (Min. With CIFO - (Min. Withs	n. Withstand): stand):	54 1,04	8 kV 3 kV 4 kV 9 kV	(566 kV) (472 kV) (918 kV) (972 kV)	
MECHANICAL VALUES					
Specified Mech. Lo Routine Test Load		25,000 12,500		111.2 kN 55.6 kN	

B□LT _ Ø0.75	45° [4	.6
Ø0.75 [19]		
		_
		<u>†</u>
1		
•		
T		
\mathbb{C}		
В—		Ι Λ
		A
	#F	
	7	



This drawing contains confidential information that is the property of MacLean Power L.L.C ("MacLean"). Use of MacLean's confidential information without MacLean's express written consent is strictly prohibited and may expose you to legal liability. If you believe that you received this material in error, please destroy it or return it to "MacLean Power, L.L.C., 11411 Addison, Franklin Park, IL 60131, USA."